

Product certificate number

No: 2614/0337/D1-CER

Manufacturer

**INGETEAM POWER TECHNOLOGY
Pol. Industrial El Juncarillo Nave 1, 31293 Sesma, Navarra, Spain**

Type

1Play

Model

**INGECON SUN 2.5TL M / INGECON SUN 2.7TL M / INGECON SUN 3TL M /
INGECON SUN 3.3TL M / INGECON SUN 3.68TL M / INGECON SUN 4.6TL M /
INGECON SUN 5TL M / INGECON SUN 5.5TL M / INGECON SUN 6TL M**

Type of generating unit

Static Power Converter

Technical Data

Nominal Power	2,5 kW	2,7 kW	3 kW
	3,3 kW	3,68 kW	4,6 kW
	5 kW	5,5 kW	6 kW

Nominal Voltage 220 / 230 / 240 V

Nominal Frequency 50 Hz

Firmware version ABE1000

Number of phases Single phase

Isolation Transformer NO

Standard

EN 50438:2013. Requirements for micro-generating plants to be connected in parallel with public low-voltage distribution networks

This certificate is based upon the test results of the Test Report nº 2614/0337-D1.

The above-mentioned generating unit is certified according the SGS internal process 4 based on the requirements of the UNE-EN ISO / IEC 17065.

This certificate is valid until: 12th of June 2018

Madrid, 12th of June 2015

Daniel Arranz Muñiz
Certification Manager

